



Underwriters Laboratories (UL LLC) Safety Report

Model: CUS150M (may be prefixed and followed by alphanumeric characters - See model differences section for details of nomenclature)
CUS100ME (may be prefixed and followed by alphanumeric characters - See model differences section for details of nomenclature)

Device Description: Switch-mode power supplies

Applicant: TDK-Lambda UK Ltd
Kingsley Avenue, Ilfracombe
Devon, EX34 8ES UNITED KINGDOM

Manufacturer: Same as Applicant

Manufacturing Facility(ies): TDK-Lambda UK Ltd
Kingsley Avenue, Ilfracombe
Devon, EX34 8ES UNITED KINGDOM

PANYU TRIO MICROTRONIC CO. LTD
SHIJI INDUSTRIAL ESTATE
DONGYONG, NANSHA, GUANGZHOU GUANGDONG CHINA

Report No.: E349607-D1003-1/A2/C0-ULCB

Report (Re)Issue Date: 2017-04-14; 2017-09-25 (A1); 2018-03-21 (A2)

Base Standard(s): ANSI/AAMI ES60601-1: A1:2012, C1:2009/(R)2012 and A2:2010/(R)2012, CSA CAN/CSA-C22.2 NO. 60601-1:14, IEC 60601-1 Edition 3.1 (2012)

Additional Standards: EN 60601-1:2006/A1:2013, KS C IEC 60601-1, ANSI/AAMI ES60601-1: A1:2012, C1:2009/(R)2012 and A2:2010/(R)2012, CSA CAN/CSA-C22.2 NO. 60601-1:14, BS EN 60601:2006 A1, SS-EN 60601-1:2006+A11:2011+A1:2013+AC1:2014+A12:2014

Report Types: This report consists of the following report types:
[Yes] US Certification (UL Recognition)
[Yes] CAN Certification (cUL Recognition)
[Yes] CB Report & Certificate
[No] IEC/EN Informative Report

This report covers the Safety evaluation of the referenced model(s) according to the standard(s) specified above.

The **CB Certificate** is provided as a separate enclosure to this report and not provided in the body of this report.

Table of Contents

CB - IEC REPORT:	1
Test Report.....	1
TABLE: List of critical components.....	166
National Differences.....	171
APPENDIX A: Enclosures (Page Section: A)	1
Collateral/Particular Standard Enclosures	1
Other Enclosures	2
Diagrams - (01) 01 TX100 (CUS150M-12).....	4
Diagrams - (02) 02 Common mode choke L1	6
Diagrams - (03) 03 PFC choke L2	7
Diagrams - (04) 04 Differential mode choke L3	9
Diagrams - (05) 05 Chassis	10
Diagrams - (06) 06 TX100 (CUS150M-48).....	13
Insulation diagram - (01) Insulation Diagram	15
Licences - (01) 01 X capacitor Carli MPX Certificate	16
Licences - (02) 02 Y capacitor Kemet ERP 610 certificate	17
Licences - (03) 03 X capacitor Kemet R46 certificate	21
Licences - (04) 04 Y capacitor Murata KX certificate	24
Licences - (05) 05 X capacitor Xiamen MKP62 certificate	25
Licences - (06) 06 Y capacitor Xiamen (Faratronic) MKP67 certificate	26
Licences - (07) 07 X capacitor Vishay MKP338 certificate	28
Licences - (08) 08 X capacitor Okaya Electric LE certificate	29
Licences - (09) 09 X capacitors Kemet PHE840 certificate	30
Licences - (10) 10 Y capacitor Kemet PME295 certificate	32
Licences - (11) 11 Y capacitor Vishay VY1 certificate	34
Licences - (12) 12 Thermistor Murata PRF18 certificate	35
Licences - (13) 13 TIW Furukawa TEX-E certificate	36
Licences - (14) 14 TIW-2LZ and 3LZ SIQ test report	37
Manuals - (01) CUS100ME Handbook	59
Manuals - (02) CUS150M Handbook	66
Marking label - (01) CUS100ME Marking label	73
Marking label - (02) CUS150M Marking label	74
Marking label - (03) CUS150MD Marking label	75
Miscellaneous - (01) 01 Declaration of manufacturing locations	76
Miscellaneous - (02) 02 Output parameters table	77
Photographs - (01) 01 Overall view, open frame	79
Photographs - (02) 02 Overall view, U chassis	80
Photographs - (03) 03 Overall view, top cover	81
Photographs - (04) 04 Overall view, top fan.....	82
Photographs - (05) 05 PWB top	83
Photographs - (06) 06 PWB bottom	84
Photographs - (07) 07 Top view, top cover	85
Photographs - (08) 08 Top view, top fan	86
Photographs - (09) 09 U chassis	87
Photographs - (10) 10 Top cover.....	88
Photographs - (11) 11 Top fan	89
Photographs - (12) 12 Chassis insulation (U chassis, top cover version)	90
Photographs - (13) 13 Chassis insulation (top fan version)	91
Schematics and PWB - (01) 01 PWB top layout	92
Schematics and PWB - (02) 02 PWB bottom layout	93
Schematics and PWB - (03) CUS100ME top and bottom PWB	94
Schematics and PWB - (04) CUS150M and CUS100ME Schematics	96
UL CERTIFICATION DOCUMENTATION:	1
APPENDIX B: UL Certification Documentation (Page Section: B)	1
Test Record.....	2
APPENDIX C: Follow-Up Service Documentation (Page Section: C)	1
Follow-Up Service Procedure.....	2
UL Authorization Page	3
UL Appendix:.....	6
GENERIC INSPECTION INSTRUCTIONS	6
INSTRUCTIONS AND DUTIES FOR UL REPRESENTATIVE	7
INSTRUCTIONS FOR FOLLOW-UP TESTS AT UL	13
RESPONSIBILITIES AND REQUIREMENTS FOR MANUFACTURER	14
GENERAL TERMINOLOGY	18
GENERAL PRODUCT CONSTRUCTION REQUIREMENTS	19
UL CERTIFICATION MARK	28
Description	29
Markings and instructions	35
Special Instructions to UL Representative	35
Production-Line Testing Requirements	35
TABLE: List of Critical Components	37
TEST RESULTS:	1
APPENDIX D: Test Datasheets Enclosures (Page Section: D)	1
CERTIFICATE OF COMPLIANCE	1

Report Modifications Summary

The following changes were made to this report. If none listed in the below table, this report is the originally issued report.

The following scheme is used throughout this report to reflect the **Report No.:**

(File No.) – (Report Ref. No.) – (x) / A(y) / C(z) – YYY, where:

(x) = Report (Re)Issue No.


(y) = Amendment No.

(z) = Correction No.

YYY = Report Type (UL/CB/IEC)

*NOTE: The **CB Certificate** may not be updated for report corrections that don't affect the CB Certificate contents; therefore if this report includes a correction number (z), it may not be reflected in the CB Certificate.*


Date Modified (Year-Month-Day)	Modifications Made (include Report Reference Number)	Modified By
2017-08-29	Amendment 1: measurements of earth leakage current and touch current repeated per client's request (E349607-D1003-1/A1/C0-ULCB)	Hubert Koszewski
2018-03-21	<p>Amendment 2:</p> <p>Technical amendment was issued in order to add CUS100ME, CUS150M-15, CUS150M-18, CUS150M-28, CUS150M-36 and DC rated version of CUS150M series. Due to the modification following report sections were modified: general product information, insulation table, clause list and test tables. Only limited testing was considered necessary due to similarity to previously evaluated construction.</p> <p>This amendment shall be read in conjunction with the Original CB Report No.E349607-D1003-1/A0/C0-ULCB and Amendment-1 issue 2017-08-29.</p>	Krzysztof Wasilewski



Test Report issued under the responsibility of:



IEC 60601-1	
Medical electrical equipment	
Part 1: General requirements for basic safety and essential performance	
Report Reference No.:	E349607-D1003-1/A2/C0-ULCB
Date of issue	2017-04-14; 2017-09-25 (A1); 2018-03-21 (A2)
Total number of pages	177
CB Testing Laboratory	UL International Polska Sp. z o.o. Aleja Krakowska 81 05-090 Sekocin Nowy Warszawy POLAND
Applicant's name	TDK-Lambda UK Ltd
Address	Kingsley Avenue, Ilfracombe Devon, EX34 8ES UNITED KINGDOM
Test specification:	
Standard	IEC 60601-1:2005 (Third Edition) + CORR. 1:2006 + CORR. 2:2007 + A1:2012 (or IEC 60601-1: 2012 reprint)
Test procedure	CB Scheme
Non-standard test method.....:	N/A
Test Report Form No.....:	IEC60601_1K
Test Report Form Originator	UL(US)
Master TRF	2015-11
Copyright © 2015 Worldwide System for Conformity Testing and Certification of Electrotechnical Equipment and Components (IECEE), Geneva, Switzerland. All rights reserved.	
This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.	
This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.	
General disclaimer:	
The test results presented in this report relate only to the object tested.	
This report shall not be reproduced, except in full, without the written approval of the Issuing CB testing laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.	

<p>Test item description:</p> <p>Trade Mark:</p> <p>Manufacturer:</p> <p>Model/Type reference:</p> <p>Ratings:</p>	<p>Switch-mode power supplies</p> <p>Trademark image(s):</p>  <p>Same as Applicant</p> <p>CUS150M (may be prefixed and followed by alphanumeric characters - See model differences section for details of nomenclature)</p> <p>CUS100ME (may be prefixed and followed by alphanumeric characters - See model differences section for details of nomenclature)</p> <p>Input:</p> <p>CUS150M-xxVx/yyyy 100-240Vac; 47-63Hz; 2.2Arms Max.</p> <p>CUS150MD-xxVx/yyyy 133-318Vdc, 1.8A</p> <p>CUS100ME-xxVx/yyyy 100-240Vac; 47-63Hz; 1.4Arms Max.</p> <p>Output:</p> <p>CUS100ME-12/yyyy output: 12-13.2Vdc 8.33A CUS100ME-15/yyyy output: 15-16.5Vdc 6.66A CUS100ME-18/yyyy output: 18-19.8Vdc 5.55A CUS100ME-24/yyyy output: 24-26.4Vdc 4.16A CUS100ME-28/yyyy output: 28-30.8Vdc 3.57A CUS100ME-36/yyyy output: 36-39.6Vdc 2.77A CUS100ME-48/yyyy output: 48-50Vdc 2.08A</p> <p>CUS150M-12/yyyy output: 12-13.2Vdc 12.5A CUS150M-15/yyyy output: 15-16.5Vdc 10A CUS150M-18/yyyy output: 18-19.8Vdc 8.33A CUS150M-24/yyyy output: 24-26.4Vdc 6.25A CUS150M-28/yyyy output: 28-30.8Vdc 5.4A CUS150M-36/yyyy output: 36-39.6Vdc 4.2A CUS150M-48/yyyy output: 48-50Vdc 3.125A</p> <p>Each output has a range shown in the table above which is factory configurable only.</p> <p>For further details please see model differences section.</p>
<p>Testing procedure and testing location:</p>	

<input checked="" type="checkbox"/> CB Testing Laboratory:		
Testing location/ address:	UL International Polska Sp. z o.o. Aleja Krakowska 81 05-090 Sekocin Nowy Warszawy POLAND	
<input type="checkbox"/> Associated CB Testing Laboratory:		
Testing location/ address:		
Tested by (name, function, signature):	Krzysztof Wasilewski, Project Handler	<i>Krzysztof Wasilewski</i>
Approved by (name, function, signature):	Bruno Motta, Reviewer	<i>Bruno F. Motta</i>
<hr/>		
<input type="checkbox"/> Testing procedure: CTF Stage 1:		
Testing location/ address:		
Tested by (name, function, signature):		
Approved by (name, function, signature):		
<hr/>		
<input type="checkbox"/> Testing procedure: CTF Stage 2		
Testing location/ address:		
Tested by (name, function, signature):		
Witnessed by (name, function, signature):		
Approved by (name, function, signature):		
<hr/>		
<input type="checkbox"/> Testing procedure: CTF Stage 3:		
<input type="checkbox"/> Testing procedure: CTF Stage 4:		
Testing location/ address:		
Tested by (name, function, signature):		
Witnessed by (name, function, signature):		
Approved by (name, function, signature):		
Supervised by (name, function, signature):		
<hr/>		

List of Attachments (including a total number of pages in each attachment):

Refer to Appendix A of this report. All attachments are included within this report.

Summary of testing

Tests performed (name of test and test clause):

Testing location:

Refer to the Test List in Appendix D of this report if testing was performed as part of this evaluation.

Summary of compliance with National Differences

List of countries addressed: Austria, Korea, Republic of, USA, Canada, United Kingdom, Sweden

[X] The product fulfils the requirements of IEC 60601-1:2005 (Third Edition) + CORR. 1:2006 + CORR. 2:2007 + A1:2012

(or IEC 60601-1: 2012 reprint).

Copy of marking plate

The artwork below may be only a draft. The use of certification marks on a product must be authorized by the respective NCBs that own these marks.

Refer to the enclosure(s) titled Marking Label in the Enclosures section in Appendix A of this report for a copy.

GENERAL INFORMATION	
Test item particulars (see also Clause 6):	
Classification of Installation and Use:	Component part of host equipment
Device type (component/sub-assembly/ equipment/ system):	Component Switch Mode Power Supply
Intended use (Including type of patient, application location):	To supply regulated power
Mode of Operation:	Continuous
Supply Connection:	Connection to Mains via host equipment
Accessories and detachable parts included:	None
Other Options Include:	None
Testing	
Date of receipt of test item(s)	2017-01-12, 2017-01-19, 2017-01-27; 2017-07-11 (A1); 2018-01-03, 2018-01-12, 2018-01-15 (A2)
Dates tests performed	2017-02-17 to 2017-02-28, 2017-03-3 to 2017-03-06, 2017-04-04; 2017-07-20 (A1); 2018-02-22 to 2018-03-14 (A2)
Possible test case verdicts:	
- test case does not apply to the test object	N/A
- test object does meet the requirement.....	Pass (P)
- test object was not evaluated for the requirement	N/E
- test object does not meet the requirement.....	Fail (F)
Abbreviations used in the report:	
- normal condition: N.C.	- single fault condition: S.F.C.
- means of Operator protection: MOOP	- means of Patient protection: MOPP
General remarks:	
<p>Before starting to use the TRF please read carefully the 4 instructions pages at the end of the report on how to complete the new version "K" of TRF for IEC for 60601-1 3rd edition with Amendment 1.</p> <p>"(See Attachment #)" refers to additional information appended to the report.</p> <p>"(See appended table)" refers to a table appended to the report.</p> <p>The tests results presented in this report relate only to the object tested.</p> <p>This report shall not be reproduced except in full without the written approval of the testing laboratory.</p> <p>List of test equipment must be kept on file and available for review.</p> <p>Additional test data and/or information provided in the attachments to this report.</p>	
Throughout this report a point is used as the decimal separator.	
Manufacturer's Declaration per sub-clause 4.2.5 of IEC 60601-1:2012	
The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided	Yes
When differences exist; they shall be identified in the General product information section.	

Name and address of factory (ies): TDK-Lambda UK Ltd
 Kingsley Avenue, Ilfracombe
 Devon, EX34 8ES UNITED KINGDOM

PANYU TRIO MICROTRONIC CO. LTD
 SHIJI INDUSTRIAL ESTATE
 DONGYONG, NANSHA, GUANGZHOU
 GUANGDONG CHINA

GENERAL PRODUCT INFORMATION:

Report Summary

All applicable tests according to the referenced standard(s) have been carried out.
 Refer to the Report Modifications for any modifications made to this report.

Product Description

The CUS150M is a power supply for building in to end equipment. It is available as open frame, U chassis, U chassis and lid, base plate and with a top fan version.

The power supply can be used as either a Class I or a Class II construction.

- For Class I construction, the power supply will need to be reliably earthed, professionally installed and fixed with suitable, metal screws.

-For Class II construction no earthing connection is required. The power supply needs to be fixed so that it is insulated from any unearthed accessible conductive part by reinforced insulation.

The power supply provides two fuses for input protection. One in the Live line and one in the Neutral line. Option E uses one fuse only. This is fitted in the live line only.

The power supply can be forced air (top fan or customer air), convection or conduction cooled. Due to the fact that air flow for cooling depends on end product use, only convection cooling and top fan configurations were considered during temperature measurement.

The component temperatures listed in the additional information shall not be exceeded.

Model Differences

The CUS has two ranges of 100W and 150W each with seven nominal output voltages of 12, 15, 18, 24, 28, 36 and 48 Volt. Each output has a range shown in the table below which is factory configurable only.

CUS models as described below:

Units may be marked with a Product Code: CUSZ-xxVx/yyyy where Z is 100ME or 150M and x may be any number of numbers or left blank to indicate the output voltage. V represents a decimal place when required or can left be left blank. y can be blank or any number of numbers or letters (excluding M, E, U, A, F, B, H) when indicating non-safety related model differences. y can be M, E, U, A, F, B when indicating the standard options as listed below.

Unit Product Code may be prefixed by K, SP # and/or NS # followed by / or - (where # may be any number of characters indicating non-safety related model differences).

Unit Product Code:

CUSZ-xxVx/yyyy

Where:

Z = 150M for 150W model (may be followed by 'D' for DC input), 100ME for 100W model

xxVx = Channel 1 output voltage from within the output voltage adjustment range from the Output Parameters Tables below.

yyyy = Unit options from list of standard unit options below, or non-safety related model differences:

/M = Molex connectors

/E = Single fuse in the live line

/U = U chassis

/A = Cover and U chassis

/F = Top fan, cover and U chassis (CUS150M model only)

/B = Baseplate

Input Parameters

Nominal input voltage:	100 - 240Vac,	133 - 318Vdc*
Input voltage range :	85 - 264Vac,	120 - 350Vdc*
Input frequency range:	47 - 63Hz,	DC*
Maximum input current:	2.2A rms (CUS150M), 1.4A rms (CUS100ME)	1.8A*

* 60601-1 2nd ed, 300Vdc input max. DC rating applies for CUS150M family only.

All ratings apply for ambient temperatures up to 50°C. (see Variations and Limitations below)

Output power is reduced linearly by 10% for input voltages from 90 to 85Vac

Output Parameters

There are seven CUS150M and CUS100ME standard models as shown in the tables below. All of these models may be fan(CUS150M model only), forced air, conduction or convection cooled. The output parameters are shown in the tables below.

Outputs are not user adjustable but can be factory set.

CUS150M

Model	Vout Range (V)	*Fan Vnom (V)	Max Iout (A)	Max Pout (W)	*Fan Inom (A)	Output ratings Pnom (W)
12	12-13.2	11.6	12.5	150	0.5	5.8
15	15-16.5	9.8	10	150	0.5	4.9
18	18-19.8	11.6	8.33	150	0.5	5.8
24	24-26.4	11.6	6.25	150	0.5	5.8
28	28-30.8	10.8	5.4	150	0.5	5.4
36	36-39.6	11.6	4.2	150	0.5	5.8
48	48-50	11.6	3.125	150	0.5	5.8

* Fan output tracks Vout Range

Variation and Limitations:

Customer Forced Air Cooling max ambient 85°C (note 1)

Convection and conduction/cold plate Cooling (U chassis with lid-Option A) max ambient 75°C (note 1)

Convection and conduction/cold plate Cooling (U chassis and open frame) max ambient 80°C (note 1)

Fan supplied ratings/Option F max ambient 70°C, from 50°C to 70°C the output power is de-rated by 0.5°C per watt

Note 1. Maximum output power and current ratings are dependent on the ambient used in the end equipment.

CUS100M

Model	Vout Range (V)	Max Iout (A)	Max Pout (W)
12	12-13.2	8.33	100
15	15-16.5	6.66	100
18	18-19.8	5.55	100
24	24-26.4	4.16	100
28	28-30.8	3.57	100
36	36-39.6	2.77	100
48	48-50	2.08	100

Variation and Limitations:

Customer Forced Air Cooling max ambient 85°C (note 1)

Convection and conduction/cold plate Cooling (U chassis with lid-Option A) max ambient 75°C (note 1)

Convection and conduction/cold plate Cooling (U chassis and open frame) max ambient 80°C (note 1)

Note 1. Maximum output power and current ratings are dependent on the ambient used in the end equipment.

Additional Information

Cooling for units with forced air cooling (Except option F)

The product can also operate at input voltage lowered to 85Vac with linear output de-rating to -10%.

The following method must be used for determining the safe operation of PSUs.

The components listed in the following table must not exceed the temperatures given. To determine the component temperatures the heating tests must be conducted in accordance with the requirements of the standard in question. Consideration should also be given to the requirements of other safety standards.

Test requirements include: PSU to be fitted in its end-use equipment and operated under the most adverse conditions permitted in the end-use equipment handbook/specification and which will result in the highest temperatures in the PSU. To determine the most adverse conditions consideration should be given to the end use equipment maximum operating ambient, the PSU loading and input voltage, ventilation, end use equipment orientation, the position of doors & covers, etc. Temperatures should be monitored using type K fine wire thermocouples (secured with cyanoacrylate adhesive or similar) placed on the hottest part of the component (out of any direct airflow) and the equipment should be run until all temperatures have stabilized.

CUS150M Cooling for Unit Temperature Table:

Circuit Ref.	Description Max.	Temperature (°C)
L1	Common Mode Choke	110 (130)
L2	PFC choke 125	(130)
L3	Differential mode choke	125 (130)
C1	Film capacitor	105
C2, C110	Electrolytic Capacitors	86 (105)

C6, C102, C104, C105	Electrolytic Capacitors	92 (105)
C3	X Capacitor	100
C5, C100, C101, C103,	Y Capacitors	105
TX100	Transformer Winding	110
XU101, XU102	Opto-Coupler 100	(110)
XD8	Diode	130
J1	Input Connector	105
J100	Output Connector	105

CUS100ME Cooling for Unit Temperature Table:

Circuit Ref.	Description Max.	Temperature(°C)
L1	Common Mode Choke	110 (130)
L2	PFC choke	125 (130)
L3	Differential mode choke	125 (130)
C1	Film capacitor	105
C2	Electrolytic Capacitors	90 (105)
C104, C105	Electrolytic Capacitors	92 (105)
C6, C102	Electrolytic Capacitors	93 (105)
C3	X Capacitor	100
C5, C100, C101, C103,	Y Capacitors	105
TX100	Transformer Winding	110
XU101, XU102	Opto-Coupler	100 (110)
XD8	Diode	130
J1	Input Connector	105
J100	Output Connector	105

Higher temperature limits (in brackets) may be used but product life may be reduced.

Technical Considerations

- The product was investigated to the following standards:

Main Standard(s):

ANSI/AAMI ES60601-1: A1:2012, C1:2009/(R)2012 and A2:2010/(R)2012, CSA CAN/CSA-C22.2 NO. 60601-1:14, IEC 60601-1 Edition 3.1 (2012)

From Country Differences:

- Austria: EN 60601-1:2006/A1:2013
- Korea, Republic of: KS C IEC 60601-1
- USA: ANSI/AAMI ES60601-1: A1:2012, C1:2009/(R)2012 and A2:2010/(R)2012
- Canada: CSA CAN/CSA-C22.2 NO. 60601-1:14
- United Kingdom: BS EN 60601:2006 A1
- Sweden: SS-EN 60601-1:2006+A11:2011+A1:2013+AC1:2014+A12:2014

Additional Standards:

EN 60601-1:2006/A1:2013, KS C IEC 60601-1, ANSI/AAMI ES60601-1: A1:2012, C1:2009/(R)2012 and A2:2010/(R)2012, CSA CAN/CSA-C22.2 NO. 60601-1:14, BS EN 60601:2006 A1, SS-EN 60601-1:2006+A11:2011+A1:2013+AC1:2014+A12:2014

- The following additional investigations were conducted: n/a

- The product was not investigated to the following standards or clauses: Biocompatibility, PESS, EMC, Annex Z of EN standards for compliance with the MDD
- The following accessories were investigated for use with the product: n/a
- No Other Considerations.

Engineering Conditions of Acceptability

When installed in an end-product, consideration must be given to the following:

The following production line tests are conducted for this product: Electric Strength, Earthing Continuity

The following output terminals were referenced to earth during performance testing: All outputs and their return lines individually referenced to earth to obtain maximum working voltage

The power supply terminals and/or connectors are: not investigated for field wiring

The maximum investigated branch circuit rating is: 20A

The investigated pollution degree is: II

Proper bonding to the end product main protective earthing termination is: required in a Class I application

The following magnetic devices (e.g. transformers or inductor) are provided with an OBJY2 insulation system with the indicated rating greater than Class A (105°C): TX100 (class B)

The following end-product enclosures are required: Mechanical, Fire, Electrical

EMC compliance has not been verified nor has it been taken into consideration. An accredited EMC Test Report will be required in conjunction with the Certification of the end product.

All models require component temperatures to be monitored as detailed in the additional information.

The end-product Dielectric Strength Test is to be based upon a maximum working voltage of: Primary-Secondary: 240 Vrms, 480 Vpk, Primary-Earthed Dead Metal: 350 Vrms, 410 Vpk, Secondary outputs-Earthed Dead Metal: 240Vrms, 340Vpk.

Report Modifications

Date Modified (Year-Month-Day)	Modifications Made (include Report Reference Number)	Modified By
2017-08-29	Amendment 1: measurements of earth leakage current and touch current repeated per client's request (E349607-D1003-1/A1/C0-ULCB)	Hubert Koszewski
2018-03-21	Amendment 2: Technical amendment was issued in order to add CUS100ME, CUS150M-15, CUS150M-18, CUS150M-28, CUS150M-36 and DC rated version of CUS150M series. Due to the modification following report sections were modified: general product information, insulation table, clause list and test tables. Only limited testing was considered necessary due to similarity to previously evaluated construction. This amendment shall be read in conjunction with the Original CB Report No.E349607-D1003-1/A0/C0-ULCB and Amendment-1 issue 2017-08-29.	Krzysztof Wasilewski