

US-TUVR-012409

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Ratings and principal characteristics

Trademark (if any)

Customer's Testing Facility (CTF) Stage used Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Power Supply

TDK-Lambda Americas Inc. 401 Mile of Cars Way, Suite 325 National City CA 91950, USA

TDK-Lambda Americas Inc. 401 Mile of Cars Way, Suite 325 National City CA 91950, USA

See additional page(s)

3 AC 400-480V, 50-60Hz

1),2) 6A (per phase); 3),4),5) 8A (per phase); 4600W; Class I

Output: see associated test report

TDK-Lambda

CTF Stage 1

1) TPS3000-24-xxx, 2) TPS3000-48-xxx, 3) TPS4000-24-xxx, 4) TPS4000-12-xxx, 5) TPS4000-48-xxx


(x = A-Z, 0-9, blank)

IEC 62368-1:2014

for national differences see test report

31583701

This CB Test Certificate is issued by the National Certification Body



2020-10-09

TUV Rheinland of North America, Inc. 12 Commerce Road Newtown CT 06470 - USA Web:www.tuv.com

Signature: Martin Glagla

0/061 CB 06/20v9 rl

Date:



Ref. Certif. No.

US-TUVR-012409

Page 2 of 2

- TDK-Lambda Malaysia Sdn. Bhd. Lot 2 & 3, Batu 9 3/4 Kawasan Perindustrian Bandar Baru Jaya Gading 26070 Kuantan Pahang, Malaysia
- 2. TDK-Lambda Americas Inc. 405 Essex Rd. Neptune NJ 07753 USA

Additional information (if necessary)

Report Ref. No.: 31583701 300

Moedin flage_

Date: 2020-10-09 Signature: Martin Glagla