

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE**CERTIFICAT D'ESSAI OC**

Product
Produit

Switching Power Supply for Building-in

Name and address of the applicant
Nom et adresse du demandeur

TDK-LAMBDA CORP
NAGAOKA TECHNICAL CENTER
R&D DIV
2704-1 SETTAYA-MACHI NAGAOKA-SHI
NIIGATA 940-1195 JAPAN

Name and address of the manufacturer
Nom et adresse du fabricant

TDK-LAMBDA CORP
NAGAOKA TECHNICAL CENTER
R&D DIV
2704-1 SETTAYA-MACHI NAGAOKA-SHI
NIIGATA 940-1195 JAPAN

Name and address of the factory
Nom et adresse de l'usine

TDK-LAMBDA MALAYSIA SDN BHD
LOT 2 & 3, BATU 9 3/4 KAWASAN PERINDUSTRIAN BANDAR
BARU JAYA GADING 26070 KUANTAN
MALAYSIA

Note: When more than one factory, please report on page 2
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2^{eme} page

Additional Information on page 2
See Page 2

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

Trademark (if any)
Marque de fabrique (si elle existe)

Type of Manufacturer's Testing Laboratories used
Type de programme du laboratoire d'essais
constructeur

Model / Type Ref.
Ref. De type

HWS1000L-X /BATz, HWS1000L-X /YYYYYYY,
SWS1000L-X /YYYYYYY See Page 2

Additional information (if necessary may also be
reported on page 2)
Les informations complémentaires (si nécessaire,,
peuvent être indiqués sur la 2^{eme} page

Additionally evaluated to EN 60950-1:2006 /A11:2009 /A1:2010
/A12:2011 /A2:2013. National Differences specified in the CB Test
Report.

Additional Information on page 2

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

IEC 60950-1(ed.2), IEC 60950-1(ed.2);am1, IEC
60950-1(ed.2);am2

As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

E122103-A190-CB-2 issued on 2016-12-15

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/nbnames

Date: 2016-12-16

Signature:

Akira Kato



Ref. Certif. No.

JP-14027-UL

Model Details:

HWS1000L-X /YYYYYYY, SWS1000L-X /YYYYYYY, where X can be 3, 5, 12, 15, 24, 36, 48, or 60. And, /YYYYYYY can be /RF, /RFHC, /RFCO2, /HC, /HCCO2, /CO2, /RFHCCO2, /LLF, /LLFCO2, /LNF1 (only for X is 48) or blank

HWS1000L-X /BATz, where X can be 36 or 60. And, z can be 3 digit max which consist of 0 to 9 and/or A to Z or blank.

Factories:

WUXI TDK-LAMBDA ELECTRONICS CO LTD
NO 6 XING CHUANG ER LU WUXI JIANGSU 214028
CHINA

ALPS LOGISTICS FACILITIES CO LTD
593-1 NISHIOHASHI TSUKUBA-SHI IBARAKI-KEN 305-0831
JAPAN

SENDAN ELECTRONICS MFG CO LTD
1010 HABUSHIN NANTO-SHI TOYAMA-KEN 939-1756
JAPAN

Ratings:

Input:

100-240 Vac, 13A, 50/60 Hz.

Output:

HWS1000L-3, SWS1000L-3, +3.3Vdc, 200A;
HWS1000L-5, SWS1000L-5, +5Vdc (+4 - +6Vdc), 200A max;
HWS1000L-12, SWS1000L-12, +12Vdc (+9.6 - +14.4Vdc), 88A max;
HWS1000L-15, SWS1000L-15, +15Vdc (+12 - +19.5Vdc), 70A max;
HWS1000L-24, SWS1000L-24, +24Vdc (+19.2 - +28.8Vdc), 44A max;
HWS1000L-36, SWS1000L-36, +36Vdc (+28.8 - +43.2Vdc), 29A max;
HWS1000L-48, SWS1000L-48, +48Vdc (+38.4 - +56Vdc), 22A max;
HWS1000L-60, SWS1000L-60, +60Vdc (+48 - +66 Vdc), 17A max

Additional information (if necessary)

Information complémentaire (si nécessaire)



- UL (US), 333 Pflingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2016-12-16

Signature:

Akira Kato