

# **GSP 15kW/10kW**

## *RELIABILITY*

## *DATA*

DWG: IA852-79-01		
APPD	CHK	DWG
<i>Osamu</i> 26/11/18	<i>Osamu</i> 26/11/18	<i>MICHAEL C.</i> 26. 11. 2018

**TDK-LAMBDA**

INDEX	PAGE
1.MTBF; Calculated Value of MTBF	R-1
2.Vibration Test	R-2

The above data is typical value. As all units have nearly the same characteristics, the data to be considered as ability value.

## M.T.B.F.

Calculation based on parts stress reliability projection of Telcordia (Bellcore)  
 "Reliability Prediction Procedure for Electronic Equipment" Document number TR-322, Issue5)  
 Individual failure  $\lambda_{SS}$  is calculated from electrical stress and temperature rise of each device.

$$MTBF = \frac{1}{\lambda_{equip}} = \frac{1}{\pi_E \sum_{i=1}^m N_i \cdot \lambda_{SSi}} \times 10^9 \text{ (hours)}$$

$$\lambda_{SSi} = \lambda_{Gi} \cdot \pi_{Qi} \cdot \pi_{Si} \cdot \pi_{Ti}$$

- $\lambda_{equip}$  : Total Equipment failure rate (FITs = Failures in  $10^9$  hours)
- $\lambda_{Gi}$  : Generic failure rate for the  $i$ th device
- $\pi_{Qi}$  : Quality factor for the  $i$ th device
- $\pi_{Si}$  : Stress factor for the  $i$ th device
- $\pi_{Ti}$  : Temperature factor for the  $i$ th device
- $m$  : Number of different device types
- $N_i$  : Quantity of  $i$ th device type
- $\pi_E$  : Equipment environmental factor

Conditions:

Ta=25°C

Gf - Ground, Fixed, Uncontrolled

For GSP15kW: M.T.B.F. = 63069 (HOURS)

For GSP10kW: M.T.B.F. = 94603 (HOURS)

MODEL: G600-25.5 3P400


## (1) Vibration test class

Frequency variable endurance test

## (2) Equipment used


Name	Manufaturer	Model
Vibration Test System (Amplifier *SP +93-011I1, Remote Control Panel *SP 9 3-00+I1, Vibrator *SP +93-005I1, Slip Table, Driver Bar, Pomp, Fan, Head Expander)	Ling Dynamic Systems	V875
Precision Barometer, +70 - 1050 hPa	LUFFT Mess- und Regeltechnik GmbH	DKD-K-26701
Temp. & Humidity Meter, (-50 - *70) deg, (20 - 99 )% RH	Mad Electronics	HTC-1
APEX SL VIBRATION CONTROLLER	Unholtz-Dickie	APEX SL
Isotron Accelerometer 101.2 mV/Ig	Dytran Instruments Inc.	3256A2
Isotron Accelerometer 101.7 mV/Ig	Dytran Instruments Inc.	3049E3

## (3) Testing method



## Test condition:

Random frequency 10Hz~500Hz  
 Acceleration X: 0.24  
                  Y: 0.89  
                  Z: 1.25  
 Direction      X,Y,Z  
 Test time     1H.each



\*E.U.T. is fixed to vibrator surface by mounting straps

## (4) Test Result



OK

NG

Vin=400Vac; Iout=500A

Check item	Vout (V)	Ripple(mVp-p)	E.U.T.state
Directions \Initial			
Before test	600.108	190	O.K.
X	600.146	200	O.K.
Y	600.155	190	O.K.
Z	600.975	200	O.K.