



Test Report issued under the responsibility of:



IEC 60601-1
Medical electrical equipment
Part 1: General requirements for basic safety and essential performance

| | |
|-----------------------------------|---|
| Report Reference No. | E309264-D1018-1-CB |
| Date of issue | 2015-07-21 |
| Total number of pages | 161 |
| CB Testing Laboratory | UL Japan, Inc. |
| Address | 4383-326 Asama-cho, Ise-shi, Mie, 516-0021, Japan |
| Applicant's name | TDK-LAMBDA CORP |
| Address | NAGAOKA TECHNICAL CENTER R&D DIV 2704-1 SETTAYA-MACHI NAGAOKA-SHI NIIGATA, 940-1195 JAPAN |
| Test specification: | |
| Standard | IEC 60601-1: 2005 + CORR. 1:2006 + CORR. 2:2007 + AM1:2012 (or IEC 60601-1: 2012 reprint) |
| Test procedure | CB Scheme |
| Non-standard test method | N/A |
| Test Report Form No. | IEC60601_1J |
| Test Report Form Originator | UL(US) |
| Master TRF | 2014-07 |

Copyright © 2014 Worldwide System for Conformity Testing and Certification of Electrotechnical Equipment and Components (IECEE), Geneva, Switzerland. All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.



This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

General disclaimer:

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing CB testing laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.

| | |
|------------------------|---|
| Test item description: | Component Power Supply |
| Trade Mark: | Refer to Marking Label enclosure |
| Manufacturer: | TDK-LAMBDA CORP 2704-1 SETTAYA-MACHI NAGAOKA-SHI NIIGATA-KEN, 940-1195 JAPAN |
| Model/Type reference: | HWS150-5/ME, HWS150-12/ME, HWS150-15/ME, HWS150-24/ME, HWS150-24/ME2, HWS150-30/ME, HWS150-48/ME, HWS150- 5/MEA, HWS150-12/MEA, HWS150-15/MEA, HWS150-24/MEA, HWS150-48/MEA |
| Ratings: | HWS150-5/ME Input 100-230VAC 50/60Hz 2.1A Output 5V 30A (4-6V) HWS150-12/ME Input 100-230VAC 50/60Hz 2.1A Output 12V 13A (9.6-14.4V) HWS150-15/ME Input 100-230VAC 50/60Hz 2.1A Output 15V 10A (12-18V) HWS150-24/ME Input 100-230VAC 50/60Hz 2.1A Output 24V 6.5A (19.2-28.8V) HWS150-24/ME2 Input 100-230VAC 50/60Hz 2.1A Output 24V 6.5A (19.2-28.8V) HWS150-30/ME Input 100-230VAC 50/60Hz 2.1A Output 30V 5.2A HWS150-48/ME Input 100-230VAC 50/60Hz |

| | | |
|---|---|---|
| 2.1A Output 48V 3.3A (38.4-52.8V) | | |
| HWS150-5/MEA Input 100-230VAC 50/60Hz 2.1A Output: 5V DC 30A (4-6V) | | |
| HWS150-12/MEA Input 100-230VAC 50/60Hz 2.1A Output 12V 13A (9.6-14.4V) | | |
| HWS150-15/MEA Input 100-230VAC 50/60Hz 2.1A Output 15V 10A (12-18V) | | |
| HWS150-24/MEA Input 100-230VAC 50/60Hz 2.1A Output 24V 6.5A (19.2-28.8V) | | |
| HWS150-48/MEA Input 100-230VAC 50/60Hz 2.1A Output: 48V 3.3A (38.4-52.8V) | | |
| Testing procedure and testing location: | | |
| <input checked="" type="checkbox"/> CB Testing Laboratory: | | |
| Testing location/ address: | UL Japan, Inc. 4383-326 Asama-cho, Ise-shi, Mie, 516-0021, Japan | |
| <input type="checkbox"/> Associated CB Testing Laboratory: | | |
| Testing location/ address: | | |
| Tested by (name + signature): | Toshinori Mori |  |
| Approved by (name + signature): | Tsutomu Abe |  |

| | | |
|--|--|--|
| [] Testing procedure: TMP/CTF Stage 1: | | |
| Testing location/ address: | | |
| Tested by (name + signature): | | |
| Approved by (name + signature): | | |
| [] Testing procedure: WMT/CTF Stage 2: | | |
| Testing location/ address: | | |
| Tested by (name + signature): | | |
| Witnessed by (name + signature): | | |
| Approved by (name + signature): | | |
| [] Testing procedure: SMT/CTF Stage 3 or 4: | | |
| Testing location/ address: | | |
| Tested by (name + signature): | | |
| Witnessed by (name + signature): | | |
| Approved by (name + signature): | | |
| Supervised by (name + signature): | | |

List of Attachments (including a total number of pages in each attachment):

Refer to Appendix A of this report. All attachments are included within this report.

Summary of testing

Tests performed (name of test and test clause):

Testing location:

Refer to the Test List in Appendix B of this report if testing was performed as part of this evaluation.

Summary of compliance with National Differences

List of countries addressed: Austria, USA, Canada, United Kingdom, Sweden

Copy of marking plate

The artwork below may be only a draft. The use of certification marks on a product must be authorized by the respective NCBs that own these marks.

Refer to the enclosure(s) titled Marking Plate in the Enclosures section in Appendix A of this report for a copy.

| | |
|--|--|
| GENERAL INFORMATION | |
| Test item particulars: | |
| Classification of Installation and Use: | Built-in |
| Device Type: | Component |
| Intended Use Statement: | To supply regulated power, no patient connection |
| Mode of Operation: | Continuous |
| Supply Connection: | None |
| Accessories and detachable parts included: | None |
| Other Options Include: | None |
| Testing | |
| Date of receipt of test item(s) | 2015-05-28 |
| Dates tests performed | 2015-06-09 to 2015-06-11 |
| Possible test case verdicts: | |
| - test case does not apply to the test object | N/A |
| - test object does meet the requirement..... | Pass (P) |
| - test object was not evaluated for the requirement | N/E |
| - test object does not meet the requirement..... | Fail (F) |
| Abbreviations used in the report: | |
| - normal condition: N.C. | - single fault condition: S.F.C. |
| - means of Operator protection: MOOP | - means of Patient protection: MOPP |
| General remarks: | |
| <p>"(See Attachment #)" refers to additional information appended to the report. "(See appended table)" refers to a table appended to the report. The tests results presented in this report relate only to the object tested. This report shall not be reproduced except in full without the written approval of the testing laboratory. List of test equipment must be kept on file and available for review. Additional test data and/or information provided in the attachments to this report.</p> | |
| Throughout this report a point is used as the decimal separator. | |
| Manufacturer's Declaration per sub-clause 4.2.5 of IEC60601-1:2012 | |
| The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided | Yes |
| When differences exist; they shall be identified in the General product information section. | |

Name and address of factory (ies): TDK-LAMBDA CORP
 2704-1 SETTAYA-MACHI
 NAGAOKA-SHI
 NIIGATA-KEN, 940-1195 JAPAN

WUXI TDK-LAMBDA ELECTRONICS CO LTD
 NO 6
 XING CHUANG ER LU
 WUXI, SINGAPORE INDUSTRIAL PARK,
 WUXI JIANGSU, 214028 P. R. CHINA

TDK-LAMBDA (MALAYSIA) SDN. BHD
 PLO33 KAWASAN PERINDUSTRIAN SENAI
 81400, SENAI JOHOR MALAYSIA

GENERAL PRODUCT INFORMATION:

Report Summary

All applicable tests according to the referenced standard(s) have been carried out.
 Refer to the Report Modifications page for any modifications made to this report.

Product Description

Component Power Supply.
 No Applied Part

Model Differences

Models HWS150-5/MEA, HWS150-12/MEA, HWS150-15/MEA, HWS150-24/MEA, HWS150-48/MEA are identical to Models HWS150-5/ME, HWS150-12/ME, HWS150-15/ME, HWS150-24/ME, HWS150-48/ME respectively except for providing Honeycombed Cover

Models HWS150-5/xx, HWS150-12/xx, HWS150-15/xx, HWS150-24/xx, HWS150-48/xx (xx: ME or MEA) are identical to each except for output voltage, output current, transformer (T2) and minor electrical circuits.

Model HWS150-30/ME is identical to Model HWS150-24/ME except for output voltage, output current and minor electrical circuits.

Model HWS150-24/ME2 is identical to Model HWS150-24/ME except for capacitance rating of Line to ground Capacitor (C2, C3).

Additional Information

The product has been previously evaluated by UL according to CB scheme to IEC 60601-1:2005 + CORR.1: 2006 + CORR.2: 2007, CB Test Report Ref. No. E309264-A16-CB-1 and Amendment 1. Tests conducted per mentioned above edition of the standard were reviewed and considered representative of the corresponding tests required by IEC 60601-1: 2005 + CORR. 1:2006 + CORR. 2:2007 + AM1:2012 as follows.

4.11 Power Input

8.4.2 Limitation of Voltage, Current or Power

8.4.3 Voltage or Charge Limitation

8.5.4 Working Voltage Measurements

8.6.4a Impedance and Current Carrying Capability

8.8.4.1 Ball Pressure

11 Temperature
 13 Abnormal Operation Testing
 15.5.1.2 Transformer Short Circuit
 15.5.1.3 Transformer Overload

Additional tests were conducted for verification, and to fill a gap between 3rd edition without Amendment 1 and 3rd edition with Amendment 1.

CB Test certificates for components are included in Licenses Enclosure. In accordance with the current rules of CB Scheme, CB Test certificate is effective for 3 years. Recognizing NCB may challenge the CBTC when certificates are more than 3 years.

When submitting this Test Report to other Certification Body, the manufacturer is responsible for providing any additional information that the Body may need in order to issue its Mark, including testing for compliance with the applicable collateral standards.

Technical Considerations

- The product was investigated to the following additional standards:
 EN 60601-1:2006/A1:2013, ANSI/AAMI ES60601-1:2005/(R)2012, CSA CAN/CSA-C22.2 NO. 60601-1:14, BS EN 60601:2006 A1, SS-EN 60601-1:2006+A11:2011+A1:2013+AC1:2014+A12:2014
 Additional: N/A
- The following additional investigations were conducted: N/A
- The product was not investigated to the following standards or clauses: Biocompatibility (ISO 10993-1), Clause 14, Programmable Electronic Systems, Electromagnetic Compatibility (IEC 60601-1-2), Risk Management
- The following accessories were investigated for use with the product: N/A
- No Other Considerations.

Engineering Conditions of Acceptability

When installed in an end-product, consideration must be given to the following:

Considerations to the applied parts requirement, to be conducted as end-product.

Consideration should be given to measuring the temperature on power electronic components and transformer windings when the power supply is installed in the end-use equipment. The end-use product shall ensure that the power supply is used within its ratings.

The output circuits have not been evaluated for direct patient connection (Type B, BF or CF)

The input/output terminals are not acceptable for field connections, they are only intended for factory wiring inside the end-use product.

The component shall be installed in compliance with the enclosure, mounting, marking, spacing, and separation requirements of the end use application.

Power supply provides the following MOOP (means of operator protection): 2MOOP based upon a working voltage 243 Vrms, 604 Vpk between Primary to Secondary, 1MOOP based upon a working voltage 243 Vrms, 604 Vpk between Primary and Earth

Temperature, Leakage Current, Protective Earthing, Dielectric Voltage Withstand, and Interruption of the Power Supply tests should be considered as part of the end product evaluation.

Proper bonding to the end-product main protective earthing termination is required.

The product was tested for use at the maximum ambient temperature (Tma) permitted by the

manufacturer's specification. See Enclosures-Miscellaneous "05 HWS150ME Derating curve" and "06 HWS150MEA Derating curve" for additional details regarding output derating depends on the product orientation.

Transformer (T2) employ a Class F (155°C) insulation system.

The products were tested on a 20 A branch circuit. If used on a branch circuit greater than this, additional testing may be necessary.

Additional fusing may be required in the end product to meet the requirement of Cl. 8.11.5, Mains fuses and Over Current Release. The product is only provided and tested with a single fuse.

The end-product evaluation shall ensure that the requirements related to Accompanying Documents, Clause 7.9 are met.

The product is suitable for use in the presence of a flammable anesthetics mixture with air or oxygen or with nitrous oxide: No

The Clearances have additionally been assessed for suitability up to 3000 m elevation.

The risk management requirements of the standard were not addressed.

The investigated Pollution Degree is : 2