



Member of the FM Global Group

FM Approvals
1151 Boston-Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

LZS-A500-3 Regulated Power Supply.

NI / I / 2 / ABCD / T3C Ta = 70°C

Special Condition of Use:

1. Must be installed in suitable equipment enclosure in accordance with ANSI/ISA S82.01 and S82.03.

Equipment Ratings:

Nonincendive apparatus for use in Class I, Division 2, Groups A, B, C & D indoor hazardous (classified) locations, temperature class is T3C at Ta = 70°C.

Approved for:

Lambda Electronics Inc
3055 Del Sol Blvd,
San Diego CA 92514

This certifies that the equipment described has been found to comply with the following FM Approval Standards and other documents:

Class 3600	1998
Class 3611	2004
Class 3810	2005

Original Project ID: 3025228

FM Approval Granted:

Subsequent Revision Reports / Date FM Approval Amended

Report Number Date

Report Number Date

11/23/05

FM Global Technologies LLC



George A. Smith
Assistant Vice President
FM Approvals

11/23/05
Date