Ref. Certif. No.
US-TUVR-9030

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

SYSTEME CEI D' ACCEPTATION MUTUELLE DE CERTIFICATS D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

Product Produit	Switch Mode Power Supply
Name and address of the applicant Nom et adresse du demandeur	TDK-Lambda Americas Inc. 401 Mile of Cars Way, Suite 325 National City, CA 91950 US
Name and address of the manufacturer Nom et adresse du fabricant	same as applicant
Name and address of the factory Nom et adresse de l'usine Note: *When more than one factory, please report on page 2* Note: *Lorsque il y plus d'une usine, veuillez utiliser la 2ème page*	TDK-LAMBDA MALAYSIA SDN BHD PLO33 KAWASAN PERINDUSTRIAN SENAI 81400 SENAI MALAYSIA
Ratings and principal characteristics Valeurs nominales et caractéristiques principales	Additional Information, see page 2
Trademark (if any) Marque de fabrique (si elle existe)	TDK-lambda
Model / Type Ref. Ref. De Type	1) CPFE1000F-12, 2) CPFE1000F-28, 3) CPFE1000F-48
Additional information (if necessary, may also be reported on page 2) Les informations complémentaires (si nécessaire, peuvent être indiqués sur la 2ème page)	Complies with requirements as well as group and national differences where applicable for CA and US as well as EU Group Differences, EU Special National Conditions. Replaces Certificate US-TUVR-7181.
A sample of the product was tested and found to be in conformity with IEC Un échantillon de ce produit a été essayé et a été considéré conforme à la CEI	IEC 60950-1+Amd1+Amd2 2nd Edition (2005)
As shown in the Test Report Ref. No. which forms part of this Certificate Comme indiqué dans le Rapport d'essais numéro de référence qui constitue partie de ce Certificat	31081075.012

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**

TÜVRheinland®
Precisely Right.

Date: July 15, 2015

Signature: Martin Glagla

Additional Information:

Ratings and principal characteristics:

AC 100-240V, 50-60Hz (Operating Range 85-265V, 47-63Hz)
1) 12A; 2),3) 16A

Class I

Output Ratings:
1) DC 9.6-14.4 (12) V, 60A, 720W max.
2) DC 22.4-33.6 (28) V, 36A, 1008W max.
3) DC 38.4-57.6 (48) V, 21A, 1008W max.

This CB Test Certificate is issued by the National Certification body TUV Rheinland of North America, Inc.
Ce Certificat d'essai OC est établi par l'Organisme National de Certification TUV Rheinland of North America, Inc.

TÜVRheinland®
Precisely Right.

Date: July 15, 2015

Signature: Martin Glagla